



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1304

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser: **Fondital S.p.A., 25079 Vobarno (BS), Italija /Italy**

preduzeto je/
set to: kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: T 1304

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Izjava proizvođača / Manufacture's statement;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 0646 /
Test report by IMP-CGT-LAB No. T 0646.

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object : **GASNI KONDENZACIONI KOTAO**
GAS CONDENSING BOILER

proizveden od /
manufactured by : **Fondital S.p.A., Via Cerreto, 40**
25079 Vobarno (BS), Italija /Italy

oznaka - tip - serija /
mark - type - series : **FONDITAL TAHITI CONDENSING...**

vrsta/type: **B₂₃, C_{13(s)}, C_{33(s)}**
kategorija/category: **II_{213P}**

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document : **SRPS EN 483:2010; SRPS EN 625:2011;**
SRPS EN 677:2011.

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002.
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002.

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical inspection until the date :

07.01.2018.

izdat od / issued by : **M.P.**
RUKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

mesto, datum / place, date

Beograd, 08.01.2018.

M. Vučko Markičević, dipl. ing.

Ime, Prezime / Name, Surname



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1304
Strana / Page: 2/2

Prilog A /
Annex A

oznaka - tip - serija /
mark - type - series :

FONDITAL TAHITI CONDENSING...

vrsta/type: B₂₃, C₁₃₍₃₎, C₃₃₍₃₎
kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
FONDITAL TAHITI CONDENSING...		
...KR 24	Q _n =6,8÷23,7 kW P _n =6,5÷22,7 kW	- samo za grejanje / for heating only
...KR 32	Q _n =9,0÷31,4 kW P _n =8,7÷30,5 kW	
...KC 24	Q _n =6,8÷23,7 kW P _n =6,5÷22,7 kW	- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
...KC 32	Q _n =9,0÷31,4 kW P _n =8,7÷30,5 kW	

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE