



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1303
Strana / Page: 1/2

Na zahtev naručiocla /
By the request of purchaser: **Fondital S.p.A., 25079 Vobarno (BS), Italija /Italy**

preduzeto je/
set to: kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report.

Broj / Number: T 1303

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Izjava proizvođača / *Manufacture's statement;*
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 0640 /
Test report by IMP-CGT-LAB No. T 0640.

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object: **GASNI KOTAO**
GAS BOILER

proizveden od /
manufactured by: **Fondital S.p.A., Via Cerreto, 40**
25079 Vobarno (BS), Italija /Italy

oznaka - tip - serija /
mark - type - series: **FONDITAL PANAREA COMPACT CTFS 24 AF**
vrsta/type: C_{12(x)}, C_{32(x)}
kategorija/category: II_{21L3R/P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document: **SRPS EN 483:2010; SRPS EN 625:2011;**

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002.
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002.

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical inspection until the date:

07.01.2018.

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15
BEOGRAD
SRBIJA
tel: +381 11 2772 151
fax: +381 11 2781 020
imp@cgf.com.rs

izdat od / issued by:
RUKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER
Vučko Markočević, dipl. ing.
Ime, Prezime / Name, Surname

mesto, datum / place, date: **M.P.**

Beograd, 08.01.2018.



SERTIFIKAT O KONTROLISANJU

INSPECTION CERTIFICATE

Broj / Number: T 1303

Strana / Page: 2/2

Prilog A /

Annex A

oznaka - tip - serija /

mark - type - series :

FONDITAL PANAREA COMPACT CTFS 24 AF

vrsta/type: C_{12(x)} C_{32(x)}

kategorija/category: II_{110BP}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
FONDITAL PANAREA COMPACT CTFS 24 AF	Q ₀ =12,5÷25,5 kW P ₀ =11,2÷23,7 kW 2H: p=20 mbar 3B/P: p=37 mbar PMS=3 bar, T _s =83° C, PMW= 8 bar 230V, 50 Hz	- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)

Inspection certificate

Sertifikat o kontrolisanju