



# Sertifikat Certificate

## SERTIFIKAT

O PREGLEDU TIPAA/ Type examination Broj / Number: T 1834

POJEDINAČNI PREGLED/Single examination Strana / Page: 1 / 2

Na zahtev naručioca /  
By the request of purchaser: Fondital S.p.A, Via Cerreto 40, 25079 Vobarno (BS),  
Italija / Italy

preduzeto je/  
has been undertaken: Kontrolisanje novog proizvoda  
the new product inspection

u vezi sa Izveštajem o usaglašenosti/  
in relation to Inspection report: Broj / Number: T 1834-3

sa dokumentima u prilogu/  
with attached documents: - Uputstvo za korišćenje / User's manual  
- Uputstvo za instaliranje / Installation instruction;  
- Dokumentacija o proizvodu / Product documentation;  
- Izveštaji o ispitivanju IQG - 12 - 013 i GP18-0029805-01-  
RP01 ; / Test reports IQG - 12 - 013 i GP18-0029805-01-  
RP01

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:  
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /  
subject of the inspection: GASNI KOTAO /  
GAS BOILER

proizveden od /  
manufactured by: Fondital S.p.A, Via Cerreto 40, 25079 Vobarno (BS),  
Italija / Italy

oznaka - tip - serija /  
mark - type - series: Fondital Antea RTFS 24, RBTF 24, CTFS 24  
Nova Florida Delfis RTFS 24, RBTF 24, CTFS 24  
vrsta/type: B22 ,C12 ,C32, C42, C52, C62, C82, C12X  
kategorija/category: II<sub>2H3B/P</sub>

kako je specificirano u Prilogu  
A, zadovoljava zahteve  
navedene u /  
as specified in the Annex A,  
meets the requirements listed in: Pravilnik o zahtevima za projektovanje, izradu i  
ocenjivanje usaglašenosti gasnih aparata ("Sl. gl.  
RS", br. 41/2015)  
SRPS EN 15502-2-1:2013

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i  
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /  
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012  
and the decree of the Ministry of Mining and Energy N<sup>o</sup> 312-01-01508/2016-05.  
Ocenjivanje sprovedeno / Evaluation performed from: 01.08.2018. - 15. 11. 2018.

izdat od / issued by:

INSTITUT MIHAJLO PUPIN  
CENTAR ZA GASNU TEHNIKU/  
INSTITUTE MIHAJLO PUPIN  
GAS TECHNIQUE CENTRE


mesto, datum / place, date:


Beograd, 15.11.2018.

M.P.  
/ S.P.

Kristina Petković dipl.maš.inž.

ime, Prezime / Name, Surname





**Prilog A /  
Annex A**

Broj / Number: T 1834  
Strana / Page: 2 / 2

oznaka - tip - serija /  
mark - type - series :

Fondital Antea RTFS 24, RBTF 24, CTFS 24  
Nova Florida Delfis RTFS 24, RBTF 24, CTFS 24  
vrsta/type: B<sub>22</sub>, C<sub>12</sub>, C<sub>32</sub>, C<sub>42</sub>, C<sub>52</sub>, C<sub>62</sub>, C<sub>82</sub>, C<sub>12X</sub>  
kategorija/category: II<sub>2H3B/P</sub>

# Sertifikat Certificate

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
Fondital Antea ... Nova Florida Delfis ...		
... CTFS 24		- CTFS za centralno grejanje i trenutnu toplu sanitarnu vodu / for central heating and instantaneous hot water
... RTFS 24	Q <sub>n</sub> =12,5 ÷ 25,5 kW P <sub>n</sub> =11,1 ÷ 23,7 kW	- RTFS samo za centralno grejanje / only for central heating
... RBTF 24	PMS=3 bar, PMW=8 bar Tmax=83°C IPX4D NOx 2 230V, 50 Hz	- RBTF centralno grejanje i priključenje na spoljni grejač sanitarne vode / central heating and connection to external water heater



INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs

**Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /**  
Any changes on the device must be reported to the issuer of this document

**Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja**  
**Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one**  
year within the assessment of the Declaration of Conformity with the type!

**Poslednja nadzorna poseta obaljena 16.05.2023. /**  
The last audit was done 16.05.2023.