



Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPAA/ Type examination

Broj / Number: T 1835

POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of
purchaser:

FONDITAL, S.p.A., Via Cerreto 40, 25079 Vobarno,
Italija / Italy

preduzeto je/
has been undertaken:

Kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number: T 1835-1

sa dokumentima u
prilogu/
with attached documents:

- Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Skup zveštaja o ispitivanju IMQ R116-0007697-01-... i
R116-0007697-02-... / Set of test reports IMQ R116-
0007697-01-... and R116-0007697-02-...

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection:

GASNI KOTAO /
GAS BOILER

proizveden od /
manufactured by:

FONDITAL, S.p.A., Via Cerreto 40, 25079 Vobarno,
Italija / Italy

oznaka - tip - serija /
mark - type - series:

Fondital Itaca CH KR ...
Nova Florida Orion CH KR ...
vrsta/type: B23, B23P, C13, C33, C43, C53, C63, C83, C93, C13X,
C33X, C43X, C63X, C93X
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu
i ocenjivanje usaglašenosti gasnih aparata ("Sl.
gl. RS", br. 41/2015)
SRPS EN 15502-2-1:2017

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.
Ocenjivanje sprovedeno / Evaluation performed from 01.08.2018.

izdat od / issued by:

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum /
place, date:

Beograd, 29.08.2018.



Ime, Prezime / Name, Surname



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs



Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

Prilog A / Annex A

Broj / Number: T 1835

Strana / Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

Fondital Itaca CH KR ...

Nova Florida Orion CH KR ...

vrsta/type: B23, B23P, C13, C33, C43, C53, C63, C83, C93, C13X,
C33X, C43X, C63X, C93X
kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
Fondital Itaca CH KR ... Nova Florida Orion CH KR ...		
... 35	$Q_n=4,0 \div 34,7$ kW $P_n=3,8 \div 33,6$ kW ^{1.)} $P_n=4,3 \div 36,7$ kW ^{2.)}	PMS=3,6 bar, Tmax=85°C IP X4D
... 45	$Q_n=4,0 \div 40,0$ kW $P_n=3,8 \div 38,5$ kW ^{1.)} $P_n=4,3 \div 41,5$ kW ^{2.)}	NOx 6 230V, 50 Hz
... 50	$Q_n=6,0 \div 47,5$ kW $P_n=5,8 \div 45,8$ kW ^{1.)} $P_n=6,5 \div 50,1$ kW ^{2.)}	PMS=4,2 bar, Tmax=85°C IP X4D
... 60	$Q_n=6,0 \div 60,0$ kW $P_n=5,8 \div 58,3$ kW ^{1.)} $P_n=6,5 \div 62,8$ kW ^{2.)}	NOx 6 230V, 50 Hz
... 70	$Q_n=9,0 \div 69,0$ kW $P_n=8,5 \div 66,8$ kW ^{1.)} $P_n=9,7 \div 72,4$ kW ^{2.)}	
... 85	$Q_n=9,0 \div 81,0$ kW $P_n=8,5 \div 78,5$ kW ^{1.)} $P_n=9,7 \div 84,8$ kW ^{2.)}	
... 99	$Q_n=11,5 \div 98,0$ kW $P_n=11,1 \div 95,2$ kW ^{1.)} $P_n=12,4 \div 105,0$ kW ^{2.)}	PMS=6 bar, Tmax=85°C IP X4D
... 120	$Q_n=11,5 \div 115,0$ kW $P_n=11,1 \div 112,0$ kW ^{1.)} $P_n=12,4 \div 122,0$ kW ^{2.)}	NOx 6 230V, 50 Hz
... 135	$Q_n=22,5 \div 130,0$ kW $P_n=20,8 \div 126,4$ kW ^{1.)} $P_n=23,2 \div 137,8$ kW ^{2.)}	
... 150	$Q_n=22,5 \div 140,0$ kW $P_n=21,6 \div 136,3$ kW ^{1.)} $P_n=23,9 \div 148,7$ kW ^{2.)}	

za grejanje i
povezivanje
na spoljni
bojler za
TSV/ for
heating and
connecting to
an external
drinking
water storage
for DHW

Napomene / notes:

1.) pri / at 80/60°C;

2.) pri / at 50/30°C ;

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /

Any changes on the device must be reported to the issuer of this document

Poslednja nadzorna poseta obaljena 16.05.2023. /

The last audit was done 16.05.2023.