



# Sertifikat Certificate

## SERTIFIKAT

O PREGLEDU TIPAA/ Type examination

Broj / Number: T 1918

POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /  
By the request of purchaser: **Fondital S.p.A, Via Cerreto 40, 25079 Vobarno (BS),  
Italija / Italy**

preduzeto je/  
has been undertaken: **Kontrolisanje novog proizvoda  
the new product inspection**

u vezi sa Izveštajem o usaglašenosti/  
in relation to Inspection report: **Broj / Number : T 1918, T 1918-1, T 1918-2**

sa dokumentima u prilogu/  
with attached documents: 

- Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju GP18-0023035-01-RP01 i GP18-0023035-02-RP01 / Test reports GP18-0023035-01-RP01 i GP18-0023035-02-RP01.

**INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:  
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:**

predmet ocenjivanja /  
subject of the inspection: **GASNI KONDENZACIONI KOTAO /  
GAS CONDENSATION BOILER**

proizveden od /  
manufactured by : **Fondital S.p.A, Via Cerreto 40, 25079 Vobarno (BS),  
Italija / Italy**

oznaka - tip - serija /  
mark - type - series : **Fondital Formentera KC/KR/KRB ...  
Nova Florida Virgo KC/KR/KRB ...  
vrsta/type: B23 , C13 , C33, C43 , C53, C63 , C83, C13X  
kategorija/category: II2H3P**

kako je specificirano u Prilogu  
A, zadovoljava zahteve  
navedene u /  
as specified in the Annex A, meets  
the requirements listed in: **Pravilnik o zahtevima za projektovanje, izradu i  
ocenjivanje usaglašenosti gasnih aparata ("Sl. gl.  
RS", br. 41/2015)  
SRPS EN 15502-2-1:2013**

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i  
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /  
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012  
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.  
Ocenjivanje sprovedeno / Evaluation performed from : 11.07.2019. - 24. 09. 2019.

izdat od / issued by :

**INSTITUT MIHAJLO PUPIN  
CENTAR ZA GASNU TEHNIKU/  
INSTITUTE MIHAJLO PUPIN  
GAS TECHNIQUE CENTRE**  
Kristina Petković dipl.maš.inž.

mesto, datum / place, date :

Beograd, 24.09.2019.

Ime , Prezime / Name , Surname



**INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs**





# Sertifikat Certificate



INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs

## Prilog A / Annex A

Broj / Number: T 1918

Strana / Page: 2 / 2

oznaka - tip - serija /  
mark - type - series :

Fondital Formentera KC/KR/KRB ...  
Nova Florida Virgo KC/KR/KRB ...

vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>43</sub>, C<sub>53</sub>, C<sub>63</sub>, C<sub>83</sub>, C<sub>13X</sub>  
kategorija/category: II<sub>2H3P</sub>

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
<b>Fondital Formentera...</b> <b>Nova Florida Virgo...</b>		
...KC/KR/KRB 12	$Q_n = 2,0 \div 12,0 \text{ kW}$ $P_n = 1,8 \div 11,7 \text{ kW}$ $P_n = 2,1 \div 12,6 \text{ kW}^*$	<b>KR</b> - samo centralno grejanje / only central heating;
...KC/KR/KRB 24	$Q_n = 3,0 \div 23,7 \text{ kW}$ $P_n = 2,6 \div 23,0 \text{ kW}$ $P_n = 3,2 \div 25,0 \text{ kW}^*$	<b>KC</b> - centralno grejanje i trenutnu toplu sanitarnu vodu / central heating and instantaneous hot water
...KC/KR/KRB 28	$Q_n = 3,3 \div 26,4 \text{ kW}$ $P_n = 3,0 \div 25,5 \text{ kW}$ $P_n = 3,5 \div 28,0 \text{ kW}^*$	<b>KRB</b> - centralno grejanje i priključenje na spoljni grejač sanitarne vode / central heating and connection to external water heater
...KC/KR/KRB 32	$Q_n = 4,2 \div 30,4 \text{ kW}$ $P_n = 3,9 \div 29,4 \text{ kW}$ $P_n = 4,4 \div 32,3 \text{ kW}^*$	

\* Napomen / Note : **Za / For** (50/30) °C

**Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. / Any changes on the device must be reported to the issuer of this document**

**Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year within the assessment of the Declaration of Conformity with the type!**

**Poslednja nadzorna poseta obavljena 16.05.2023. / The last audit was done 16.05.2023.**