



SERTIFIKAT

O PREGLEDU TIPA/ Type examination Broj / Number: T 1841

POJEDINAČNI PREGLED/Single examination Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: Robert Bosch d.o.o. Milutina Milankovića 9ž
11070 Beograd Srbija / Serbia

preduzeto je/
has been undertaken: Kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report: Broj /
Number: T 1841

sa dokumentima u prilogu/
with attached documents: - Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju DVGW B18/01/2566 EU / Test reports DVGW B18/01/2566

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: GASNI KOTAO /
GAS BOILER

proizveden od /
manufactured by : Bosch Thermotechnik Isitma ve Klima San ve Tic A.S.
Organize Sanayi Bölgesi TR-45030 Manisa Turkey

oznaka - tip - serija /
mark - type - series : Bosch Condens GC2300 (i)W...
vrsta/type: B23 , C13 , C33
kategorija/category: П2НЗВР

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in: - Pravilnik o zahtevima za projektovanje,
izradu i ocenjivanje usaglašenosti gasnih
aparata ("Sl. gl. RS", br. 41/2015)
- SRPS EN 15502-2-1:2017

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.
Ocenjivanje sprovedeno / Evaluation performed from 05. 12. 2018. ÷ 21. 12. 2018.



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

izdat od / issued by :

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum / place, date : M.P. /
S.P.A.

Beograd, 21.12.2018.

Ime , Prezime / Name , Sumame

Sertifikat
Certificate



Sertifikat Certificate

Prilog A /
Annex A

Broj /
Number: T 1841
Strana /
Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

Bosch Condens GC2300 (i)W...

vrsta/type: B₂₃, C₁₃, C₃₃
kategorija/category: II_{2H3B/P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :	
Bosch Condens...			
GC2300(i)W 24/30 C 23	Q _n =3,1÷24,5 kW P _n =3,0÷24,0 kW Q _{nw} =3,1÷30,0 kW ^{1.)}	G20:p=20mbar G30:p=30mbar PMS=3 bar, PMW=10 bar Tmax=82°C IP X4D NOx 6 (GTM) 230V, 50 Hz, 110W	za grejanje i toplu sanitarnu vodu, TSV/ for heating and domestic hot water, DHW

Napomene / notes:

1.) za TSV / for DHW

Bilo kakve promena na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs