



## SERTIFIKAT

O PREGLEDU TIPA/ Type examination Broj / Number: T 1906

POJEDINAČNI PREGLED/Single examination Strana / Page: 1 / 2

Na zahtev naručioca /  
By the request of purchaser: Vaillant d.o.o. Radnička 57, Beograd, Srbija / Serbia

preduzeto je/  
has been undertaken: Kontrolisanje novog proizvoda  
Inspection of the new product

u vezi sa Izveštajem o usaglašenosti/  
in relation to Inspection report: Broj / Number: T 1906

sa dokumentima u prilogu/  
with attached documents: - Uputstvo za instaliranje, održavanje i korisnika /  
Installation, maintenance instructions and User manual;  
- Dokumentacija ugrađenih delova / Documentation of  
embedded components;  
- Izveštaji o ispitivanju KIWA K 2108 2017 B1 rev.01 ,  
161100456 , 161100456/3 i 126030 / Test reports KIWA K  
2108 2017 B1 rev.01 , 161100456 , 161100456/3 and 126030

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:  
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /  
subject of the inspection: GASNI KONDENZACIONI KOTAO / GAS  
CONDENSING BOILER

proizveden od /  
manufactured by : Vaillant GmbH Berghauser Str.40 Remscheid, Nemačka  
/ Germany

oznaka - tip - serija /  
mark - type - series : eco TEC plus ...

vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>  
kategorija/category: II<sub>2H3P</sub>

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /  
as specified in the Annex A, meets the requirements listed in: - Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015)  
- SRPS EN 15502-2-1:2017

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /  
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 19. 02. 2019. ÷ 10.04.2019.

izdat od / issued by :

INSTITUT MIHAJLO PUPIN  
CENTAR ZA GASNU TEHNIKU/  
INSTITUTE MIHAJLO PUPIN  
GAS TECHNIQUE CENTRE  
Kristina Petković dipl.maš.inž.

mesto, datum izdavanja /  
place, date of issue:

Beograd, 10.04.2019.



Ime , Prezime / Name , Surname

Sertifikat  
Certificate



INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impct@pupin.rs



## SERTIFIKAT

O PREGLEDU TIP A / Type examination

POJEDINAČNI PREGLED / Single examination

Prilog A /  
Annex A

Broj / Number:

T 1906

Strana / Page:

2 / 2

oznaka - tip - serija /  
mark - type - series :

eco TEC plus ...

vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>  
kategorija/category: II<sub>2H3P</sub>

Sertifikat  
Certificate



INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
eco TEC plus ...		
... VU INT 806/5-5	G20* Qn = 15,2 ÷ 76,2** kW Pn = 14,9 ÷ 74,7** kW	max pritisak grejanja 6 bar / max pressure for heating 6 bar, IPX4D, 230V, 50Hz NOx 5  samo za grejanje/ for heating only
	G31* Qn = 38,1 ÷ 76,2** kW Pn = 37,4 ÷ 74,7** kW	
... VU INT 1006/5-5	G20 Qn = 19,2 ÷ 95,2** kW Pn = 18,7 ÷ 93,3** kW	
	G31 Qn = 47,6 ÷ 95,2** kW Pn = 46,7 ÷ 93,3** kW	
... VU INT 1206/5-5	G20 Qn = 22,9 ÷ 114,3** kW Pn = 22,4 ÷ 112,0** kW	
	G31 Qn = 57,2 ÷ 114,3** kW Pn = 56,0 ÷ 112,0** kW	
Napomena/note: *G20: p=20 mbar , G31: p=37 mbar ** Za / For : 80/60 °C		

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /  
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja  
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one  
year within the assessment of the Declaration of Conformity with the type!

Poslednja nadzorna poseta obavljena 11.08.2022.  
The last audit was done 11.08.2022.