



# Sertifikat Certificate

## SERTIFIKAT

O PREGLEDU TIPA / Type examination

Broj / Number: T 2025

POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /  
By the request of purchaser:

Vaillant d.o.o. Radnička 57 Beograd, Srbija/ Serbia

preduzeto je/  
has been undertaken:

Kontrolisanje novog proizvoda  
Inspection of the new product

u vezi sa Izveštajem o usaglašenosti/  
in relation to Inspection report:

Broj / Number: T 2025

sa dokumentima u  
prilogu/  
with attached documents:

- Uputstvo za instaliranje, održavanje i korisnika /  
Installation, maintenance instructions and User manual;
- Dokumentacija ugrađenih komponenti / Documentation  
of embedded components;
- Izveštaji o ispitivanju KIWA: 140101977 / Test reports  
KIWA: 140101977

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:  
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /  
subject of the inspection:

GASNI KOTLOVI / GAS BOILER

proizveden od /  
manufactured by :

Vaillant GmbH Remscheid Berghauser strasse 40  
Germany / Nemačka

oznaka - tip - serija /  
mark - type - series :

VU atmo TEC plus...  
VUV atmo TEC plus/pro ...

vrsta/type: B<sub>11BS</sub>  
kategorija/category: II<sub>2H3B/P</sub>

kako je specificirano u Prilogu  
A, zadovoljava zahteve  
navedene u /  
as specified in the Annex A, meets  
the requirements listed in:

- Pravilnik o zahtevima za projektovanje, izradu  
i ocenjivanje usaglašenosti gasnih aparata ("Sl.  
gl. RS", br. 41/2015)
- SRPS EN 15502-2-2:2015

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i  
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /  
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012  
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.  
Ocenjivanje sprovedeno / Evaluation performed from 25. 08. 2020. – 20. 10. 2020.



INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs

izdat od / issued by :

INSTITUT MIHAJLO PUPIN  
CENTAR ZA GASNU TEHNIKU/  
INSTITUTE MIHAJLO PUPIN  
GAS TECHNIQUE CENTRE  
Kristina Petković dipl.maš.inž.

mesto, datum izdavanja /  
place, date of issue:

Beograd, 20. 10. 2020.



Ime, Prezime / Name, Surname



## SERTIFIKAT

O PREGLEDU TIPa / Type examination

POJEDINAČNI PREGLED / Single examination

Prilog A /  
Annex A

oznaka - tip - serija /  
mark - type - series :

VU atmo TEC plus...  
VUW atmo TEC plus/pro ...

Broj / Number: T 2025

Strana / Page: 2 / 2

vrsta/type: B<sub>11BS</sub>  
kategorija/category: II<sub>2H3B/P</sub>

Sertifikat  
Certificate



INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs

detaljno oznaka - tip - serija mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description:	
<b>VU atmo TEC plus (H-SEE-INT) ...</b>			
... 200/5-5	Qn=7,8 ÷ 22,2 kW Pn=6,8 ÷ 20,0 kW	G20: p= 20 mbar, G30 : p = 30 mbar, NOx class 3	samo za grejanje / for heating only
... 240/5-5	Qn=9,4 ÷ 26,7 kW Pn=8,1 ÷ 24,0 kW	PMS = 3 bar, t <sub>CH</sub> =85 °C	
... 280/5-5	Qn=10,9 ÷ 31,1 kW Pn=9,5 ÷ 28,0 kW	230V, 50Hz, 97/88/88W IPX4D	
<b>VUW atmo TEC plus (H-SEE-INT) ** ...</b>			
... 200/5-5	Qn=7,8 ÷ 22,2 kW Pn=6,8 ÷ 20,0 (20,0*) kW	G20: p= 20 mbar, G30 : p = 30 mbar, NOx class 3	za grejanje i pripremu tople sanitarne vode / for heating and domestic hot water
... 240/5-5	Qn=9,4 ÷ 26,7 kW Pn=8,1 ÷ 24,0 (24,0*) kW	PMS = 3 bar, MPW = 10 bar t <sub>CH</sub> =85 °C	
... 280/5-5	Qn=10,9 ÷ 31,1 kW Pn=9,5 ÷ 28,0 (28,0*) kW	t <sub>DHW</sub> =65 °C 230V, 50Hz, 97/88/88 W IPX4D	
<b>VUW atmo TEC pro (H-SEE-INT) ** ...</b>			
... 180/5-3	Qn=8,0 ÷ 20,2 kW Pn=7,6 ÷ 18,0 (18,0*) kW	G20: p= 20 mbar, G30 : p = 30 mbar, NOx class 3	za grejanje i pripremu tople sanitarne vode / for heating and domestic hot water
... 240/5-3	Qn=9,4 ÷ 26,7 kW Pn=8,1 ÷ 24,0 (24,0*) kW	PMS = 3 bar, MPW = 10 bar t <sub>CH</sub> =85 °C	
... 280/5-3	Qn=10,9 ÷ 31,1 kW Pn=9,5 ÷ 28,0 (28,0*) kW	t <sub>DHW</sub> =65 °C 230V, 50Hz, 93,5/88/88W IPX4D	

napomene/notes

\* za toplu sanitarnu vodu / for domestic hot water

\*\* kotao sa pripremom tople sanitarne vode / boiler with domestic hot water

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. / Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year within the assessment of the Declaration of Conformity with the type!

Poslednja nadzorna poseta obavljena 03.11.2022. / The last audit was done 03.11.2022.