



SERTIFIKAT

O PREGLEDU TIP A / Type examination

POJEDINAČNI PREGLED / Single examination

Prilog A /
Annex A

Broj / Number: T 18-1514

Strana / Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

BOSCH CONDENS 2500W WBC...

vrsta/type: B₂₃, C_{13X}, C_{33X}
kategorija/category: II_{2H3B/P}

Sertifikat
Certificate

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :	
BOSCH CONDENS 2500W WBC...			
14-1 DE 23	2H: p=20 mbar Q _n =2,1÷14,4 kW (Hi) P _n =2,0÷14,0 kW ^{1.)} P _n =2,2÷15,0 kW ^{2.)}	PMS=3 bar, T _{max} =82°C 230 V, 50 Hz, IP X4D NO _x : 5	- za grejanje / for heating
24-1 DE 23	2H: p=20 mbar Q _n =3,1÷24,7 kW (Hi) P _n =3,0÷24,1 kW ^{1.)} P _n =3,3÷25,2 kW ^{2.)}		
28-1 DCE 23	2H: p=20 mbar Q _n =3,8÷24,7 kW (Hi) P _n =3,7÷24,1 kW ^{1.)} P _n =4,0÷25,2 kW ^{2.)}	PMS=3 bar, PMW=10 bar T=82°C 230 V, 50 Hz, IP X4D NO _x : 5	- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
Napomene / notes: 1.) pri / at: t ₂ /t ₁ =80/60°C 2.) pri / at: t ₂ /t ₁ =50/30°C			

Bilo kakve promena na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
Impcgt@pupin.rs



Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impopt@pupin.rs

SERTIFIKAT

O PREGLEDU TIPA/ Type examination

Broj / Number: T 18-1514

POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: **Robert Bosch d.o.o.** Milutina Milankovića 9ž
11070 Beograd Srbija / Serbia

preduzeto je/
has been undertaken: **Ocenjivanje usaglašenosti postupak PREGLED TIPA /**
Evaluation of conformity proceeding TYPE EXAMINATION

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report: Broj / Number: T 18-1514

sa dokumentima u prilogu/
with attached documents:

- Prospekt proizvoda /
- Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
- Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaj o ispitivanju T 16-1514-1; / Test report T 16-1514-1

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: **GASNI KOTAO /**
GAS BOILER

proizveden od /
manufactured by: Bosch Thermoteknik Isitma ve Klima Sanayi Ticaret
Anonim Sirketi, Organize Snayi Bölgesi 45030-Türkiye
/Manisa

oznaka - tip - serija /
mark - type - series : **BOSCH CONDENS 2500W WBC...**
vrsta/type: B₂₃, C_{13X}, C_{33X}
kategorija/category: II_{2H3B/P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in: **Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015) / Regulations on Requirements for design, construction and mark the conformity of gas appliances SG RS 41/15.**

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno od 07.02.2018. ÷ 19.02.2018. / Evaluation performed from 07.02.2018. ÷ 19.02.2018.

izdat od / issued by :

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum / place, date

Beograd, 19.02.2018.



Ime , Prezime / Name , Surname