

Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPA/ Type examination Broj / Number: T 18-1611

POJEDINAČNI PREGLED/Single examination Strana / Page: 1 / 2

Na zahtev naručioca / By the request of purchaser: Robert Bosch d.o.o. Milutina Milankovića 9ž
11070 Beograd Srbija / Serbia

preduzeto je/ has been undertaken: Kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o usaglašenosti/ in relation to Inspection report: Broj / Number: T 18-1611

sa dokumentima u prilogu/ with attached documents: - Prospekt proizvoda / Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje / Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaj o ispitivanju Kiwa broj 130601391; / Test report by Kiwa No. 130601391

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja / subject of the inspection: GASNI KOTAO / GAS BOILER

proizveden od / manufactured by: Bosch Thermotechnik GmbH, D-73249 Wernau, Germany

oznaka - tip - serija / mark - type - series: BOSCH CONDENS 5000 W ZBR...
vrsta/type: B₂₃, C_{13X}, C_{33X}
kategorija/category: П_{2H3P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u / as specified in the Annex A, meets the requirements listed in: Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015) / Regulations on Requirements for design, construction and mark the conformity of gas appliances SG RS 41/15

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 / The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

izdat od / issued by:

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.


mesto, datum / place, date:

Beograd, 14.02.2018.



Ime, Prezime / Name, Surname





SERTIFIKAT

O PREGLEDU TIP A / Type examination

POJEDINAČNI PREGLED / Single examination

**Prilog A /
Annex A**

Broj / Number: T 18-1611

Strana / Page: 2 / 2

**oznaka - tip - serija /
mark - type - series :**

BOSCH CONDENS 5000 W ZBR...

vrsta/type: **B₂₃, C_{13X}, C_{33X}**
kategorija/category: **II_{2H3P}**

detaljno oznaka - tip - serija / mark - type - series specification :		tehničke karakteristike / technical characteristics :		kratak opis / short description :
BOSCH CONDENS 5000 W				
ZBR...	70-3	2H: p=20 mbar Q _n =13,3÷64,3 kW (Hi) P _n =13,0÷62,6 kW ^{1.)} P _n =14,3÷69,5 kW ^{2.)}	PMS=4 bar, Tmax=90°C 230 V, 50 Hz, IP X4D NO _x : 5	- za grejanje / for heating
	100-3	2H: p=20 mbar Q _n =19,3÷96,5kW (Hi) P _n =19,0÷94,5 kW ^{1.)} P _n =20,8÷99,5 kW ^{2.)}		
Napomene / notes: 1.) pri / at: t ₂ /t ₁ =80/60°C 2.) pri / at: t ₂ /t ₁ =50/30°C				

**Bilo kakve promena na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document**

Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impct@pupin.rs